

Client	JIANGSU RUGAO HIGH VOLTAGE ELECTRIC APPARATUS CO.,LTD.		
Address of the client	No.1, West Huimin Road - Economic Development Zone 226500 - Rugao City - China.		
Manufacturer	JIANGSU RUGAO HIGH VOLTAGE ELECTRIC APPARATUS CO.,LTD.		
Tested samples/items	Single pole of three pole 252 kV live tank SF ₆ circuit-breaker for outdoor installation.		
Tests carried out	<p>Dielectric tests:</p> <ul style="list-style-type: none"> - Lightning impulse voltage tests (dry) - Power-frequency test voltage (dry and wet) <p>Dielectric tests on auxiliary and control circuits</p> <p>Power-frequency test voltage (wet) for installation at an altitude of 2500 meters.</p>		
Standards/Specifications	<p>IEC 62271-100 (2012-09)</p> <p>IEC 62271-1 (2011-08)</p> <p>Client's requests for power-frequency test voltage (wet) for installation at an altitude of 2500 m.</p>		
Tests date	from	November 3, 2015	to November 17, 2015

The results reported in this document relate only to the tested samples/items.
Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages	18	No. of pages annexed	8
Issue date	March 14, 2016		
Prepared	PHV - Del Giorgio Carlo, PHV - Gregori Marco <small>B5022770 2969 AUT B5022770 3059 AUT</small>		
Verified	PSV - Vidori Mauro, PMV - Magistris Paolo <small>B5022770 2158654 VER B5022770 2158660 VER</small>		
Approved	PMI - The Manager - Arcidiaco Lorenzo <small>B5022770 821814 APP</small>		

CESI S.p.A.
 Testing & Certification Division
 Testing Operations Area
 "Milan Platform"
 Manager