

INSPECTION REPORT


Test object A single-phase oil immersed power transformer

Designation DFSZ-125000/400 **Serial No.** 24-SY001

125000/125000/41000 kVA – 400/V3 / 115/V3 / 34,5 kV –
541,3/1882,7/1188,4 A – 60 Hz

Report No.
702200801-24

Revision 0



Manufacturer Changzhou Sieyuan Toshiba Transformer Co., Ltd.
No. 26 Chunjiang Road, Changzhou City, China
(location as declared by the manufacturer)

Client Changzhou Sieyuan Toshiba Transformer Co., Ltd.
No. 26 Chunjiang Road, Changzhou City, China

Date(s) of tests June 7 to 14, 2024

Inspected by KEMA B.V. ("KEMA Labs"),
Klingelbeekseweg 195, Arnhem, The Netherlands

Test location Changzhou Sieyuan Toshiba Transformer Co., Ltd.
No. 26 Chunjiang Road, Changzhou City, China

Test specification The tests were in accordance with IEC 60076-1:2011, IEC 60076-2:2011,
IEC 60076-3:2013 and IEC 60076-10:2016 and client's instructions.

Regarding Routine, Type and Special Tests

Summary and conclusion The object has complied with the relevant requirements of the standard and client's instructions.

This report applies only to the individual object tested. KEMA Labs makes no representations or warranties with respect to any device other than the object tested. It is the responsibility of the applicable device manufacturer to ensure that any other devices or units having the same name and descriptions as the test object are identical.

This report comprises 66 pages in total.

TYPE I

Issued by KEMA B.V.

Alessandro Bertani
Director,
Services & Smart Technologies

Arnhem, July 31, 2024

